

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on March 24)**

Water Level of the accumulated water (at 16:00 on March 24)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,207 mm (2 mm increase since 7:00 on March 24)	O.P.+ 3,092 mm (2 mm increase since 7:00 on March 24)	—
	Water level of Turbine Building	O.P.+ 3,100 mm (10 mm increase since 7:00 on March 24)	O.P.+ 3,143 mm (No change since 7:00 on March 24)	O.P.+ 3,064 mm (17 mm increase since 7:00 on March 24)	O.P.+ 3,041 mm (2 mm decrease since 7:00 on March 24)
	Water level of Reactor Building	O.P.+ 4,591 mm (51 mm increase since 7:00 on March 24)	O.P.+ 3,339 mm (4 mm decrease since 7:00 on March 24)	O.P.+ 3,139 mm (12 mm increase since 7:00 on March 24)	O.P.+ 3,069 mm (No change since 7:00 on March 24)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,573 mm (Increase from initial level:5,790 mm, 54 mm decrease since 7:00 on March 24) O.P.+ 3,270 mm (Increase from initial level:3,996 mm, 103 mm decrease since 7:00 on March 24) O.P.+ 4,422 mm (Water level from floor:626 mm, 9 mm increase since 7:00 on March 24)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on March 20)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 8:41 on March 19 to 9:27 on March 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:58 on March 16 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:05 on March 21 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.