

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 25)**

Water Level of the accumulated water (at 7:00 on March 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,206 mm (1 mm decrease since 16:00 on March 24)	O.P.+ 3,106 mm (14 mm increase since 16:00 on March 24)	—
	Water level of Turbine Building	O.P.+ 3,113 mm (13 mm increase since 16:00 on March 24)	O.P.+ 3,144 mm (1 mm increase since 16:00 on March 24)	O.P.+ 3,084 mm (20 mm increase since 16:00 on March 24)	O.P.+ 3,052 mm (11 mm increase since 16:00 on March 24)
	Water level of Reactor Building	O.P.+ 4,630 mm (39 mm increase since 16:00 on March 24)	O.P.+ 3,335 mm (4 mm decrease since 16:00 on March 24)	O.P.+ 3,161 mm (22 mm increase since 16:00 on March 24)	O.P.+ 3,075 mm (6 mm increase since 16:00 on March 24)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,480 mm (Increase from initial level:5,697 mm, 93 mm decrease since 16:00 on March 24) O.P.+ 3,015 mm (Increase from initial level:3,741 mm, 255 mm decrease since 16:00 on March 24) O.P.+ 4,439 mm (Water level from floor:643 mm, 17 mm increase since 16:00 on March 24)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on March 20)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:58 on March 16 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:05 on March 21 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.