

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on March 25)**

Water Level of the accumulated water (at 16:00 on March 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,205 mm (1 mm decrease since 7:00 on March 25)	O.P.+ 3,118 mm (12 mm increase since 7:00 on March 25)	—
	Water level of Turbine Building	O.P.+ 3,122 mm (9 mm increase since 7:00 on March 25)	O.P.+ 3,143 mm (1 mm decrease since 7:00 on March 25)	O.P.+ 3,095 mm (11 mm increase since 7:00 on March 25)	O.P.+ 3,062 mm (10 mm increase since 7:00 on March 25)
	Water level of Reactor Building	O.P.+ 4,624 mm (6 mm decrease since 7:00 on March 25)	O.P.+ 3,333 mm (2 mm decrease since 7:00 on March 25)	O.P.+ 3,170 mm (9 mm increase since 7:00 on March 25)	O.P.+ 3,080 mm (5 mm increase since 7:00 on March 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,404 mm (Increase from initial level:5,621 mm, 76 mm decrease since 7:00 on March 25) O.P.+ 2,865 mm (Increase from initial level:3,591 mm, 150 mm decrease since 7:00 on March 25) O.P.+ 4,448 mm (Water level from floor:652 mm, 9 mm increase since 7:00 on March 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on March 20)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:58 on March 16 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:05 on March 21 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.