

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 26)**

Water Level of the accumulated water (at 7:00 on March 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,203 mm (2 mm decrease since 16:00 on March 25)	O.P.+ 3,127 mm (9 mm increase since 16:00 on March 25)	—
	Water level of Turbine Building	O.P.+ 3,136 mm (14 mm increase since 16:00 on March 25)	O.P.+ 3,141 mm (2 mm decrease since 16:00 on March 25)	O.P.+ 3,106 mm (11 mm increase since 16:00 on March 25)	O.P.+ 3,066 mm (4 mm increase since 16:00 on March 25)
	Water level of Reactor Building	O.P.+ 4,624 mm (No change since 16:00 on March 25)	O.P.+ 3,330 mm (3 mm decrease since 16:00 on March 25)	O.P.+ 3,186 mm (16 mm increase since 16:00 on March 25)	O.P.+ 3,093 mm (13 mm increase since 16:00 on March 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,262 mm (Increase from initial level:5,479 mm, 142 mm decrease since 16:00 on March 25) O.P.+ 2,659 mm (Increase from initial level:3,385 mm, 206 mm decrease since 16:00 on March 25) O.P.+ 4,466 mm (Water level from floor:670 mm, 18 mm increase since 16:00 on March 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on March 20)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:58 on March 16 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:05 on March 21 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.