

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on March 26)**

Water Level of the accumulated water (at 16:00 on March 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,201 mm (2 mm decrease since 7:00 on March 26)	O.P.+ 3,127 mm (No change since 7:00 on March 26)	—
	Water level of Turbine Building	O.P.+ 3,143 mm (7 mm increase since 7:00 on March 26)	O.P.+ 3,139 mm (2 mm decrease since 7:00 on March 26)	O.P.+ 3,097 mm (9 mm decrease since 7:00 on March 26)	O.P.+ 3,080 mm (14 mm increase since 7:00 on March 26)
	Water level of Reactor Building	O.P.+ 4,611 mm (13 mm decrease since 7:00 on March 26)	O.P.+ 3,327 mm (3 mm decrease since 7:00 on March 26)	O.P.+ 3,181 mm (5 mm decrease since 7:00 on March 26)	O.P.+ 3,098 mm (5 mm increase since 7:00 on March 26)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,181 mm (Increase from initial level:5,398 mm, 81 mm decrease since 7:00 on March 26) O.P.+ 2,642 mm (Increase from initial level:3,368 mm, 17 mm decrease since 7:00 on March 26) O.P.+ 4,480 mm (Water level from floor:684 mm, 14 mm increase since 7:00 on March 26)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on March 20)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 10:10 on March 26 to 16:34 on March 26)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on March 26 to 16:00 on March 26)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 17:00 on March 26 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:29 on March 26 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* On March 26, 2012 (today), in the area of condensed water tanks for water desalinations (reverse osmosis membrane), it was found that water was leaked from a pipeline (anti-pressure hose) which transferred the condensed water from the water desalinations to the condensed water tanks. In order to stop the water leakage, we stopped the transfer pumps of the water desalinations (reverse osmosis membrane). By the stop of the transfer pumps, the water desalinations have been interrupted considering the balance of water volume.				

For quick publication of the data of water level, values are provided as reference values.