

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 28)**

Water Level of the accumulated water (at 7:00 on March 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,197 mm (3 mm decrease since 16:00 on March 27)	O.P.+ 3,158 mm (12 mm increase since 16:00 on March 27)	—
	Water level of Turbine Building	O.P.+ 3,175 mm (12 mm increase since 16:00 on March 27)	O.P.+ 3,134 mm (4 mm decrease since 16:00 on March 27)	O.P.+ 3,137 mm (10 mm increase since 16:00 on March 27)	O.P.+ 3,104 mm (11 mm increase since 16:00 on March 27)
	Water level of Reactor Building	O.P.+ 4,529 mm (25 mm decrease since 16:00 on March 27)	O.P.+ 3,327 mm (1 mm decrease since 16:00 on March 27)	O.P.+ 3,218 mm (12 mm increase since 16:00 on March 27)	O.P.+ 3,122 mm (12 mm increase since 16:00 on March 27)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,213 mm (Increase from initial level:5,430 mm, 14 mm increase since 16:00 on March 27) O.P.+ 3,571 mm (Increase from initial level:4,297 mm, 381 mm increase since 16:00 on March 27) O.P.+ 4,539 mm (Water level from floor:743 mm, 23 mm increase since 16:00 on March 27)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on March 20)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer suspended (Since 16:34 on March 26)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 17:00 on March 26 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:29 on March 26 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* On March 26, in the area of condensed water tanks for water desalinations (reverse osmosis membrane), certain amount of water leaked from a pipeline (anti-pressure hose) which transferred the condensed water from the water desalinations to the condensed water tanks. In order to stop the water leakage, we stopped the transfer pumps of the water desalinations (reverse osmosis membrane). In consideration of the entire water balance in the system following the stoppage of the pumps, Cesium Adsorption Apparatus and 2nd Cesium Adsorption Apparatus (Sarry) were also stopped.				

For quick publication of the data of water level, values are provided as reference values.