

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 29)**

Water Level of the accumulated water (at 7:00 on March 29)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,191 mm (4 mm decrease since 16:00 on March 28)	O.P.+ 3,175 mm (11 mm increase since 16:00 on March 28)	—
	Water level of Turbine Building	O.P.+ 3,195 mm (12 mm increase since 16:00 on March 28)	O.P.+ 3,130 mm (2 mm decrease since 16:00 on March 28)	O.P.+ 3,161 mm (13 mm increase since 16:00 on March 28)	O.P.+ 3,116 mm (2 mm increase since 16:00 on March 28)
	Water level of Reactor Building	O.P.+ 4,533 mm (7 mm decrease since 16:00 on March 28)	O.P.+ 3,326 mm (2 mm decrease since 16:00 on March 28)	O.P.+ 3,239 mm (12 mm increase since 16:00 on March 28)	O.P.+ 3,139 mm (11 mm increase since 16:00 on March 28)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,074 mm (Increase from initial level:5,291 mm, 134 mm decrease since 16:00 on March 28) O.P.+ 3,287 mm (Increase from initial level:4,013 mm, 236 mm decrease since 16:00 on March 28) O.P.+ 4,576 mm (Water level from floor:780 mm, 22 mm increase since 16:00 on March 28)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on March 20)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:32 on March 28 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 9:20 on March 28 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.