

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on March 29)**

Water Level of the accumulated water (at 16:00 on March 29)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,190 mm (1 mm decrease since 7:00 on March 29)	O.P.+ 3,183 mm (8 mm increase since 7:00 on March 29)	—
	Water level of Turbine Building	O.P.+ 3,203 mm (8 mm increase since 7:00 on March 29)	O.P.+ 3,128 mm (2 mm decrease since 7:00 on March 29)	O.P.+ 3,168 mm (7 mm increase since 7:00 on March 29)	O.P.+ 3,129 mm (13 mm increase since 7:00 on March 29)
	Water level of Reactor Building	O.P.+ 4,494 mm (39 mm decrease since 7:00 on March 29)	O.P.+ 3,326 mm (No change since 7:00 on March 29)	O.P.+ 3,247 mm (8 mm increase since 7:00 on March 29)	O.P.+ 3,146 mm (7 mm increase since 7:00 on March 29)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,108 mm (Increase from initial level:5,325 mm, 34 mm increase since 7:00 on March 29) O.P.+ 3,154 mm (Increase from initial level:3,880 mm, 133 mm decrease since 7:00 on March 29) O.P.+ 4,314 mm (Water level from floor:518 mm, 262 mm decrease since 7:00 on March 29)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on March 20)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on March 29 to 16:00 on March 29)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:32 on March 28 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 9:20 on March 28 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	· From 9:08 am to 5:25 pm on March 29, we conducted the transfer of accumulated water from the On-site Bunker Building to Process Main Building.				

For quick publication of the data of water level, values are provided as reference values.