

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 30)**

| | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
|--|--|---|--|---|---|
| Water Level of the accumulated water (at 7:00 on March 30) | Water level of Vertical Shaft | Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm) | O.P.+ 3,187 mm (3 mm decrease since 16:00 on March 29) | O.P.+ 3,194 mm (11 mm increase since 16:00 on March 29) | — |
| | Water level of Turbine Building | O.P.+ 3,213 mm (10 mm increase since 16:00 on March 29) | O.P.+ 3,125 mm (3 mm decrease since 16:00 on March 29) | O.P.+ 3,180 mm (12 mm increase since 16:00 on March 29) | O.P.+ 3,140 mm (11 mm increase since 16:00 on March 29) |
| | Water level of Reactor Building | O.P.+ 4,486 mm (8 mm decrease since 16:00 on March 29) | O.P.+ 3,326 mm (No change since 16:00 on March 29) | O.P.+ 3,259 mm (12 mm increase since 16:00 on March 29) | O.P.+ 3,136 mm (10 mm decrease since 16:00 on March 29) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | O.P.+ 4,008 mm (Increase from initial level:5,225 mm, 100 mm decrease since 16:00 on March 29) O.P.+ 2,925 mm (Increase from initial level:3,651 mm, 229 mm decrease since 16:00 on March 29) O.P.+ 4,281 mm (Water level from floor:485 mm, 33 mm decrease since 16:00 on March 29) | | |
| Situation of transfer of the accumulated water | | Unit 1 | Unit 2 * 1 | Unit 3 | Unit 4 |
| | | — | Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on March 20) | — | — |
| | | Unit 5 and 6 | | | |
| | — | | | | |
| Operation condition of water treatment facility | Cesium Adsorption Apparatus: Since 14:32 on March 28 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 9:20 on March 28 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance | | | | |
| Notes | | | | | |

For quick publication of the data of water level, values are provided as reference values.