

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on March 31)**

Water Level of the accumulated water (at 16:00 on March 31)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,184 mm (No change since 7:00 on March 31)	O.P.+ 3,180 mm (3 mm decrease since 7:00 on March 31)	—
	Water level of Turbine Building	O.P.+ 3,240 mm (7 mm increase since 7:00 on March 31)	O.P.+ 3,124 mm (No change since 7:00 on March 31)	O.P.+ 3,139 mm (9 mm decrease since 7:00 on March 31)	O.P.+ 3,139 mm (5 mm decrease since 7:00 on March 31)
	Water level of Reactor Building	O.P.+ 4,497 mm (31 mm increase since 7:00 on March 31)	O.P.+ 3,326 mm (3 mm increase since 7:00 on March 31)	O.P.+ 3,223 mm (7 mm decrease since 7:00 on March 31)	O.P.+ 3,134 mm (3 mm decrease since 7:00 on March 31)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,078 mm (Increase from initial level:5,295 mm, 28 mm increase since 7:00 on March 31) O.P.+ 2,533 mm (Increase from initial level:3,259 mm, 98 mm decrease since 7:00 on March 31) O.P.+ 4,322 mm (Water level from floor:526 mm, 11 mm increase since 7:00 on March 31)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on March 20)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:26 on March 30)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:32 on March 28 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 9:20 on March 28 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.