

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 2)**

Water Level of the accumulated water (at 7:00 on April 2)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,190 mm (6 mm increase since 16:00 on April 1)	O.P.+ 3,159 mm (6 mm decrease since 16:00 on April 1)	—
	Water level of Turbine Building	O.P.+ 3,269 mm (10 mm increase since 16:00 on April 1)	O.P.+ 3,129 mm (6 mm increase since 16:00 on April 1)	O.P.+ 3,113 mm (7 mm decrease since 16:00 on April 1)	O.P.+ 3,108 mm (13 mm decrease since 16:00 on April 1)
	Water level of Reactor Building	O.P.+ 4,460 mm (37 mm decrease since 16:00 on April 1)	O.P.+ 3,317 mm (6 mm decrease since 16:00 on April 1)	O.P.+ 3,191 mm (11 mm decrease since 16:00 on April 1)	O.P.+ 3,133 mm (9 mm decrease since 16:00 on April 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,195 mm (Increase from initial level:5,412 mm, 47 mm increase since 16:00 on April 1) O.P.+ 2,123 mm (Increase from initial level:2,849 mm, 155 mm decrease since 16:00 on April 1) O.P.+ 4,365 mm (Water level from floor:569 mm, 17 mm increase since 16:00 on April 1)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on March 20)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:26 on March 30)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:32 on March 28 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 9:20 on March 28 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.