

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on April 2)**

Water Level of the accumulated water (at 16:00 on April 2)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,198 mm (8 mm increase since 7:00 on April 2)	O.P.+ 3,153 mm (6 mm decrease since 7:00 on April 2)	—
	Water level of Turbine Building	O.P.+ 3,275 mm (6 mm increase since 7:00 on April 2)	O.P.+ 3,136 mm (7 mm increase since 7:00 on April 2)	O.P.+ 3,109 mm (4 mm decrease since 7:00 on April 2)	O.P.+ 3,107 mm (1 mm decrease since 7:00 on April 2)
	Water level of Reactor Building	O.P.+ 4,400 mm (60 mm decrease since 7:00 on April 2)	O.P.+ 3,325 mm (8 mm increase since 7:00 on April 2)	O.P.+ 3,187 mm (4 mm decrease since 7:00 on April 2)	O.P.+ 3,129 mm (4 mm decrease since 7:00 on April 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,223 mm (Increase from initial level:5,440 mm, 28 mm increase since 7:00 on April 2) O.P.+ 2,038 mm (Increase from initial level:2,764 mm, 85 mm decrease since 7:00 on April 2) O.P.+ 4,376 mm (Water level from floor:580 mm, 11 mm increase since 7:00 on April 2)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on March 20)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:26 on March 30)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on April 2 to 16:00 on April 2)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:32 on March 28 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 9:20 on March 28 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.