

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 4)**

Water Level of the accumulated water (at 7:00 on April 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,232 mm (20 mm increase since 16:00 on April 3)	O.P.+ 3,148 mm (3 mm increase since 16:00 on April 3)	—
	Water level of Turbine Building	O.P.+ 3,304 mm (13 mm increase since 16:00 on April 3)	O.P.+ 3,166 mm (14 mm increase since 16:00 on April 3)	O.P.+ 3,102 mm (4 mm increase since 16:00 on April 3)	O.P.+ 3,093 mm (1 mm increase since 16:00 on April 3)
	Water level of Reactor Building	O.P.+ 4,452 mm (99 mm increase since 16:00 on April 3)	O.P.+ 3,367 mm (19 mm increase since 16:00 on April 3)	O.P.+ 3,182 mm (4 mm increase since 16:00 on April 3)	O.P.+ 3,117 mm (No change since 16:00 on April 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,091 mm (Increase from initial level:5,308 mm, 128 mm decrease since 16:00 on April 3) O.P.+ 2,005 mm (Increase from initial level:2,731 mm, 102 mm increase since 16:00 on April 3) O.P.+ 4,422 mm (Water level from floor:626 mm, 19 mm increase since 16:00 on April 3)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on March 20)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:08 on April 3)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:32 on March 28 In operation 2nd Cesium Adsorption Apparatus (Sarry): From 9:20 on March 28 to 8:30 on April 4 Operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	Given the decreasing treated water volume, we stopped the 2nd Cesium Adsorpotion Apparatus (Sarry) at 8:30 am and cleaned its filter.				

For quick publication of the data of water level, values are provided as reference values.