

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on April 4)**

Water Level of the accumulated water※ (at 16:00 on April 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,239 mm (7 mm increase since 7:00 on April 4)	O.P.+ 3,145 mm (3 mm decrease since 7:00 on April 4)	—
	Water level of Turbine Building	O.P.+ 3,312 mm (8 mm increase since 7:00 on April 4)	O.P.+ 3,172 mm (6 mm increase since 7:00 on April 4)	O.P.+ 3,098 mm (4 mm decrease since 7:00 on April 4)	O.P.+ 3,095 mm (2 mm increase since 7:00 on April 4)
	Water level of Reactor Building	O.P.+ 4,461 mm (9 mm increase since 7:00 on April 4)	O.P.+ 3,367 mm (No change since 7:00 on April 4)	O.P.+ 3,176 mm (6 mm decrease since 7:00 on April 4)	O.P.+ 3,114 mm (3 mm decrease since 7:00 on April 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,019 mm (Increase from initial level:5,236 mm, 72 mm decrease since 7:00 on April 4) O.P.+ 2,173 mm (Increase from initial level:2,899 mm, 168 mm increase since 7:00 on April 4) O.P.+ 4,431 mm (Water level from floor:635 mm, 9 mm increase since 7:00 on April 4)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on March 20)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:08 on April 3)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on April 4 to 16:00 on April 4)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:32 on March 28 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 11:30 on April 4 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	In the second cesium adsorption apparatus, because we observed the treated volume gradually decreased, we temporarily stopped the apparatus to wash the filter at 8:30 am today. At 11:20 am, we restarted the apparatus and the flow rate reached the normal volume at 11:30 am.				

※ For quick publication of the data of water level, values are provided as reference values.