

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 6)**

Water Level of the accumulated water (at 7:00 on April 6)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,258 mm (7 mm increase since 16:00 on April 5)	O.P.+ 3,148 mm (10 mm increase since 16:00 on April 5)	—
	Water level of Turbine Building	O.P.+ 3,338 mm (11 mm increase since 16:00 on April 5)	O.P.+ 3,188 mm (5 mm increase since 16:00 on April 5)	O.P.+ 3,121 mm (28 mm increase since 16:00 on April 5)	O.P.+ 3,091 mm (3 mm increase since 16:00 on April 5)
	Water level of Reactor Building	O.P.+ 4,393 mm (26 mm decrease since 16:00 on April 5)	O.P.+ 3,390 mm (7 mm increase since 16:00 on April 5)	O.P.+ 3,200 mm (30 mm increase since 16:00 on April 5)	O.P.+ 3,111 mm (4 mm increase since 16:00 on April 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,714 mm (Increase from initial level:4,931 mm, 115 mm decrease since 16:00 on April 5) O.P.+ 3,060 mm (Increase from initial level:3,786 mm, 331 mm increase since 16:00 on April 5) O.P.+ 4,475 mm (Water level from floor:679 mm, 17 mm increase since 16:00 on April 5)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on March 20)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:32 on March 28 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 1:05 on April 5 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.