

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on April 6)**

Water Level of the accumulated water (at 16:00 on April 6)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,240 mm (18 mm decrease since 7:00 on April 6)	O.P.+ 3,156 mm (8 mm increase since 7:00 on April 6)	—
	Water level of Turbine Building	O.P.+ 3,344 mm (6 mm increase since 7:00 on April 6)	O.P.+ 3,172 mm (16 mm decrease since 7:00 on April 6)	O.P.+ 3,132 mm (11 mm increase since 7:00 on April 6)	O.P.+ 3,099 mm (8 mm increase since 7:00 on April 6)
	Water level of Reactor Building	O.P.+ 4,393 mm (No change since 7:00 on April 6)	O.P.+ 3,383 mm (7 mm decrease since 7:00 on April 6)	O.P.+ 3,212 mm (12 mm increase since 7:00 on April 6)	O.P.+ 3,117 mm (6 mm increase since 7:00 on April 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,768 mm (Increase from initial level:4,985 mm, 54 mm increase since 7:00 on April 6) O.P.+ 3,116 mm (Increase from initial level:3,842 mm, 56 mm increase since 7:00 on April 6) O.P.+ 4,487 mm (Water level from floor:691 mm, 12 mm increase since 7:00 on April 6)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:08 on April 6)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:32 on March 28 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 1:05 on April 5 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	*We transferred the accumulated water from the basement of the Unit 2 Turbine Building to Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) (from 10:14 am on March 20 to 9:43 am on April 6)				

For quick publication of the data of water level, values are provided as reference values.