

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on April 9)**

Water Level of the accumulated water (at 16:00 on April 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,120 mm (26 mm increase since 7:00 on April 9)	O.P.+ 3,214 mm (8 mm increase since 7:00 on April 9)	—
	Water level of Turbine Building	O.P.+ 3,017 mm (7 mm increase since 7:00 on April 9)	O.P.+ 3,066 mm (25 mm increase since 7:00 on April 9)	O.P.+ 3,195 mm (9 mm increase since 7:00 on April 9)	O.P.+ 3,156 mm (10 mm increase since 7:00 on April 9)
	Water level of Reactor Building	O.P.+ 4,242 mm (8 mm decrease since 7:00 on April 9)	O.P.+ 3,261 mm (2 mm increase since 7:00 on April 9)	O.P.+ 3,276 mm (9 mm increase since 7:00 on April 9)	O.P.+ 3,168 mm (5 mm increase since 7:00 on April 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,570 mm (Increase from initial level:5,787 mm, 11 mm decrease since 7:00 on April 9) O.P.+ 3,080 mm (Increase from initial level:3,806 mm, 7 mm increase since 7:00 on April 9) O.P.+ 4,580 mm (Water level from floor:784 mm, 11 mm increase since 7:00 on April 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Transfer Completed (From 10:08 on April 6 to 9:21 on April 9)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on April 9 to 16:00 on April 9)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:32 on March 28 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 1:05 on April 5 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.