

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 10)**

Water Level of the accumulated water (at 7:00 on April 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,186 mm (66 mm increase since 16:00 on April 9)	O.P.+ 3,226 mm (12 mm increase since 16:00 on April 9)	—
	Water level of Turbine Building	O.P.+ 3,029 mm (12 mm increase since 16:00 on April 9)	O.P.+ 3,123 mm (57 mm increase since 16:00 on April 9)	O.P.+ 3,207 mm (12 mm increase since 16:00 on April 9)	O.P.+ 3,165 mm (9 mm increase since 16:00 on April 9)
	Water level of Reactor Building	O.P.+ 4,257 mm (15 mm increase since 16:00 on April 9)	O.P.+ 3,316 mm (55 mm increase since 16:00 on April 9)	O.P.+ 3,289 mm (13 mm increase since 16:00 on April 9)	O.P.+ 3,180 mm (12 mm increase since 16:00 on April 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,486 mm (Increase from initial level:5,703 mm, 84 mm decrease since 16:00 on April 9) O.P.+ 3,087 mm (Increase from initial level:3,813 mm, 7 mm increase since 16:00 on April 9) O.P.+ 4,598 mm (Water level from floor:802 mm, 18 mm increase since 16:00 on April 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:32 on March 28 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 1:05 on April 5 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.