

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 11)**

Water Level of the accumulated water (at 7:00 on April 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,275 mm (54 mm increase since 16:00 on April 10)	O.P.+ 3,220 mm (7 mm decrease since 16:00 on April 10)	—
	Water level of Turbine Building	O.P.+ 3,046 mm (11 mm increase since 16:00 on April 10)	O.P.+ 3,206 mm (51 mm increase since 16:00 on April 10)	O.P.+ 3,187 mm (20 mm decrease since 16:00 on April 10)	O.P.+ 3,164 mm (6 mm decrease since 16:00 on April 10)
	Water level of Reactor Building	O.P.+ 4,231 mm (7 mm increase since 16:00 on April 10)	O.P.+ 3,400 mm (51 mm increase since 16:00 on April 10)	O.P.+ 3,271 mm (20 mm decrease since 16:00 on April 10)	O.P.+ 3,186 mm (1 mm decrease since 16:00 on April 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,410 mm (Increase from initial level:5,627 mm, 100 mm decrease since 16:00 on April 10) O.P.+ 2,681 mm (Increase from initial level:3,407 mm, 217 mm decrease since 16:00 on April 10) O.P.+ 4,328 mm (Water level from floor:532 mm, 17 mm decrease since 16:00 on April 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 13:31 on April 10)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:32 on March 28 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 9:50 on April 10 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.