Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 16)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on April 16)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,206 mm (3 mm increase since 16:00 on April 15)	O.P.+ 3,171 mm (6 mm decrease since 16:00 on April 15)	—
	Water level of Turbine Building	O.P.+ 3,130 mm (10 mm increase since 16:00 on April 15)	O.P.+ 3,145 mm (3 mm increase since 16:00 on April 15)	O.P.+ 3,120 mm (8 mm decrease since 16:00 on April 15)	O.P.+ 3,116 mm (9 mm decrease since 16:00 on April 15)
	Water level of Reactor Building	O.P.+ 4,187 mm (8 mm decrease since 16:00 on April 15)	O.P.+ 3,344 mm (11 mm increase since 16:00 on April 15)	O.P.+ 3,202 mm (8 mm decrease since 16:00 on April 15)	O.P.+ 3,139 mm (4 mm decrease since 16:00 on April 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building	O.P.+ 4,096 mm (Increase from initial level:5,313 mm, 113 mm decrease since 16:00 on April 15)		
		High Temperature Incinerator Building	O.P.+ 2,736 mm (Increase from initial level:3,462 mm, 85 mm increase since 16:00 on April 15)		
		On-site Bunker Building	O.P.+ 4,433 mm (Water level from floor:637 mm, 12 mm increase since 16:00 on April 15)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		_	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:27 on April 14)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 13:31 on April 10)	_
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:32 on March 28 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 9:50 on April 10 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	The level of the accumulated water in the injection valve pit of Unit 2 circulating water pump was almost stable around the level before transfer although there was a tendency of increase after the water transfer to Unit 2 Turbine Building (from February 20 to 22). At 8:04 am on April 16, we started transferring the accumulated water to the basement of Unit 2 Turbine Building.				

For quick publication of the data of water level, values are provided as reference values.