

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 18)**

Water Level of the accumulated water (at 7:00 on April 18)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,237 mm (6 mm decrease since 16:00 on April 17)	O.P.+ 3,173 mm (11 mm increase since 16:00 on April 17)	—
	Water level of Turbine Building	O.P.+ 3,159 mm (8 mm increase since 16:00 on April 17)	O.P.+ 3,172 mm (5 mm decrease since 16:00 on April 17)	O.P.+ 3,143 mm (18 mm increase since 16:00 on April 17)	O.P.+ 3,112 mm (9 mm increase since 16:00 on April 17)
	Water level of Reactor Building	O.P.+ 4,189 mm (23 mm increase since 16:00 on April 17)	O.P.+ 3,373 mm (2 mm decrease since 16:00 on April 17)	O.P.+ 3,226 mm (22 mm increase since 16:00 on April 17)	O.P.+ 3,128 mm (5 mm increase since 16:00 on April 17)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,760 mm (Increase from initial level:4,977 mm, 105 mm decrease since 16:00 on April 17) O.P.+ 2,655 mm (Increase from initial level:3,381 mm, 171 mm decrease since 16:00 on April 17) O.P.+ 4,475 mm (Water level from floor:679 mm, 15 mm increase since 16:00 on April 17)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:27 on April 14)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:32 on March 28 In operation 2nd Cesium Adsorption Apparatus (Sarry): From 9:50 on April 10 to 8:45 on April 18 Operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	At 8:45 am of April 18, we temporarily stopped the 2nd Cesium Adsorption Apparatus (Sarry) in order to implement washing of the filter.				

For quick publication of the data of water level, values are provided as reference values.