

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 19)**

|   |  |   |  |  |  |
|---|--|---|--|--|--|
| Water Level of the accumulated water<br>(at 7:00 on April 19) |  | Unit 1  | Unit 2   | Unit 3   | Unit 4   |
|   | Water level of Vertical Shaft  | Unmeasurable due to drawdown of water level<br>(Less than O.P.+ 850 mm)   | O.P.+ 3,230 mm<br>(4 mm decrease since 16:00 on April 18)  | O.P.+ 3,191 mm<br>(10 mm increase since 16:00 on April 18) | —  |
|   | Water level of Turbine Building  | O.P.+ 3,174 mm<br>(9 mm increase since 16:00 on April 18)   | O.P.+ 3,165 mm<br>(4 mm decrease since 16:00 on April 18)  | O.P.+ 3,165 mm<br>(14 mm increase since 16:00 on April 18) | O.P.+ 3,128 mm<br>(10 mm increase since 16:00 on April 18) |
|   | Water level of Reactor Building  | O.P.+ 4,181 mm<br>(5 mm decrease since 16:00 on April 18)   | O.P.+ 3,367 mm<br>(5 mm decrease since 16:00 on April 18)  | O.P.+ 3,246 mm<br>(13 mm increase since 16:00 on April 18) | O.P.+ 3,144 mm<br>(10 mm increase since 16:00 on April 18) |
|   | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building<br>High Temperature Incinerator Building<br>On-site Bunker Building   | O.P.+ 3,702 mm (Increase from initial level:4,919 mm, 103 mm decrease since 16:00 on April 18)<br>O.P.+ 2,677 mm (Increase from initial level:3,403 mm, 170 mm decrease since 16:00 on April 18)<br>O.P.+ 4,273 mm (Water level from floor:477 mm, 11 mm increase since 16:00 on April 18) |  |  |
| Situation of transfer of the accumulated water                |  | Unit 1  | Unit 2 * 1   | Unit 3   | Unit 4   |
|   |  | —   | Basement of Unit 2 Turbine Building<br>→Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building)<br>Currently being transferred<br>(Since 15:27 on April 14)   | —  | —  |
|   |  | Unit 5 and 6  |  |  |  |
|   |  | —   |  |  |  |
| Operation condition of water treatment facility               |  | Cesium Adsorption Apparatus: Since 14:32 on March 28 In operation<br>2nd Cesium Adsorption Apparatus (Sarry): Since 16:28 on April 18 In operation<br>Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance<br>Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance |  |  |  |
| Notes   |  |   |  |  |  |

For quick publication of the data of water level, values are provided as reference values.