

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on April 19)**

Water Level of the accumulated water (at 16:00 on April 19)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,228 mm (2 mm decrease since 7:00 on April 19)	O.P.+ 3,197 mm (6 mm increase since 7:00 on April 19)	—
	Water level of Turbine Building	O.P.+ 3,178 mm (4 mm increase since 7:00 on April 19)	O.P.+ 3,162 mm (3 mm decrease since 7:00 on April 19)	O.P.+ 3,171 mm (6 mm increase since 7:00 on April 19)	O.P.+ 3,136 mm (8 mm increase since 7:00 on April 19)
	Water level of Reactor Building	O.P.+ 4,163 mm (18 mm decrease since 7:00 on April 19)	O.P.+ 3,363 mm (4 mm decrease since 7:00 on April 19)	O.P.+ 3,254 mm (8 mm increase since 7:00 on April 19)	O.P.+ 3,150 mm (6 mm increase since 7:00 on April 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,646 mm (Increase from initial level:4,863 mm, 56 mm decrease since 7:00 on April 19) O.P.+ 2,582 mm (Increase from initial level:3,308 mm, 95 mm decrease since 7:00 on April 19) O.P.+ 4,280 mm (Water level from floor:484 mm, 7 mm increase since 7:00 on April 19)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:27 on April 14)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on April 19 to 16:00 on April 19)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:32 on March 28 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 16:28 on April 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.