

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 23)**

Water Level of the accumulated water (at 7:00 on April 23)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,151 mm (43 mm decrease since 16:00 on April 22)	O.P.+ 3,176 mm (6 mm decrease since 16:00 on April 22)	—
	Water level of Turbine Building	O.P.+ 3,218 mm (7 mm increase since 16:00 on April 22)	O.P.+ 3,094 mm (38 mm decrease since 16:00 on April 22)	O.P.+ 3,122 mm (9 mm decrease since 16:00 on April 22)	O.P.+ 3,119 mm (9 mm decrease since 16:00 on April 22)
	Water level of Reactor Building	O.P.+ 4,140 mm (2 mm decrease since 16:00 on April 22)	O.P.+ 3,310 mm (35 mm decrease since 16:00 on April 22)	O.P.+ 3,204 mm (9 mm decrease since 16:00 on April 22)	O.P.+ 3,138 mm (7 mm decrease since 16:00 on April 22)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,146 mm (Increase from initial level:4,363 mm, 65 mm decrease since 16:00 on April 22) O.P.+ 3,078 mm (Increase from initial level:3,804 mm, 312 mm increase since 16:00 on April 22) O.P.+ 4,348 mm (Water level from floor:552 mm, 12 mm increase since 16:00 on April 22)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:27 on April 14)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:33 on April 20)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:32 on March 28 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 16:28 on April 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.