

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on April 23)**

Water Level of the accumulated water (at 16:00 on April 23)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,132 mm (19 mm decrease since 7:00 on April 23)	O.P.+ 3,170 mm (6 mm decrease since 7:00 on April 23)	—
	Water level of Turbine Building	O.P.+ 3,223 mm (5 mm increase since 7:00 on April 23)	O.P.+ 3,079 mm (15 mm decrease since 7:00 on April 23)	O.P.+ 3,117 mm (5 mm decrease since 7:00 on April 23)	O.P.+ 3,116 mm (3 mm decrease since 7:00 on April 23)
	Water level of Reactor Building	O.P.+ 4,138 mm (2 mm decrease since 7:00 on April 23)	O.P.+ 3,290 mm (20 mm decrease since 7:00 on April 23)	O.P.+ 3,200 mm (4 mm decrease since 7:00 on April 23)	O.P.+ 3,134 mm (4 mm decrease since 7:00 on April 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,113 mm (Increase from initial level:4,330 mm, 33 mm decrease since 7:00 on April 23) O.P.+ 3,254 mm (Increase from initial level:3,980 mm, 176 mm increase since 7:00 on April 23) O.P.+ 4,355 mm (Water level from floor:559 mm, 7 mm increase since 7:00 on April 23)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:27 on April 14)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:33 on April 20)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:32 on March 28 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 16:28 on April 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.