

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on April 24)**

Water Level of the accumulated water (at 16:00 on April 24)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,132 mm (No change since 7:00 on April 24)	O.P.+ 3,160 mm (4 mm decrease since 7:00 on April 24)	—
	Water level of Turbine Building	O.P.+ 3,235 mm (5 mm increase since 7:00 on April 24)	O.P.+ 3,077 mm (2 mm decrease since 7:00 on April 24)	O.P.+ 3,103 mm (6 mm decrease since 7:00 on April 24)	O.P.+ 3,103 mm (6 mm decrease since 7:00 on April 24)
	Water level of Reactor Building	O.P.+ 4,162 mm (9 mm decrease since 7:00 on April 24)	O.P.+ 3,285 mm (2 mm decrease since 7:00 on April 24)	O.P.+ 3,186 mm (6 mm decrease since 7:00 on April 24)	O.P.+ 3,122 mm (4 mm decrease since 7:00 on April 24)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,020 mm (Increase from initial level:4,237 mm, 35 mm decrease since 7:00 on April 24) O.P.+ 3,430 mm (Increase from initial level:4,156 mm, 70 mm increase since 7:00 on April 24) O.P.+ 4,373 mm (Water level from floor:577 mm, 7 mm increase since 7:00 on April 24)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:27 on April 14)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:33 on April 20)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	—	(From 10:00 on April 24 to 16:00 on April 24)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:32 on March 28 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 16:28 on April 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.