

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 25)**

Water Level of the accumulated water (at 7:00 on April 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,127 mm (5 mm decrease since 16:00 on April 24)	O.P.+ 3,152 mm (8 mm decrease since 16:00 on April 24)	—
	Water level of Turbine Building	O.P.+ 3,242 mm (7 mm increase since 16:00 on April 24)	O.P.+ 3,073 mm (4 mm decrease since 16:00 on April 24)	O.P.+ 3,095 mm (8 mm decrease since 16:00 on April 24)	O.P.+ 3,094 mm (9 mm decrease since 16:00 on April 24)
	Water level of Reactor Building	O.P.+ 4,185 mm (23 mm increase since 16:00 on April 24)	O.P.+ 3,277 mm (8 mm decrease since 16:00 on April 24)	O.P.+ 3,177 mm (9 mm decrease since 16:00 on April 24)	O.P.+ 3,113 mm (9 mm decrease since 16:00 on April 24)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,963 mm (Increase from initial level:4,180 mm, 57 mm decrease since 16:00 on April 24) O.P.+ 3,545 mm (Increase from initial level:4,271 mm, 115 mm increase since 16:00 on April 24) O.P.+ 4,384 mm (Water level from floor:588 mm, 11 mm increase since 16:00 on April 24)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:27 on April 14)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:33 on April 20)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:32 on March 28 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 16:28 on April 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.