

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on April 25)**

Water Level of the accumulated water (at 16:00 on April 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,122 mm (5 mm decrease since 7:00 on April 25)	O.P.+ 3,147 mm (5 mm decrease since 7:00 on April 25)	—
	Water level of Turbine Building	O.P.+ 3,247 mm (5 mm increase since 7:00 on April 25)	O.P.+ 3,069 mm (4 mm decrease since 7:00 on April 25)	O.P.+ 3,089 mm (6 mm decrease since 7:00 on April 25)	O.P.+ 3,090 mm (4 mm decrease since 7:00 on April 25)
	Water level of Reactor Building	O.P.+ 4,163 mm (22 mm decrease since 7:00 on April 25)	O.P.+ 3,265 mm (12 mm decrease since 7:00 on April 25)	O.P.+ 3,172 mm (5 mm decrease since 7:00 on April 25)	O.P.+ 3,109 mm (4 mm decrease since 7:00 on April 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,926 mm (Increase from initial level:4,143 mm, 37 mm decrease since 7:00 on April 25) O.P.+ 3,622 mm (Increase from initial level:4,348 mm, 77 mm increase since 7:00 on April 25) O.P.+ 4,391 mm (Water level from floor:595 mm, 7 mm increase since 7:00 on April 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:27 on April 14)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:33 on April 20)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Currently being transferred (From 10:00 on April 25 to 16:00 on April 25)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:32 on March 28 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 16:28 on April 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.