

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 26)**

Water Level of the accumulated water (at 7:00 on April 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,110 mm (12 mm decrease since 16:00 on April 25)	O.P.+ 3,140 mm (7 mm decrease since 16:00 on April 25)	—
	Water level of Turbine Building	O.P.+ 3,253 mm (6 mm increase since 16:00 on April 25)	O.P.+ 3,058 mm (11 mm decrease since 16:00 on April 25)	O.P.+ 3,081 mm (8 mm decrease since 16:00 on April 25)	O.P.+ 3,080 mm (10 mm decrease since 16:00 on April 25)
	Water level of Reactor Building	O.P.+ 4,143 mm (20 mm decrease since 16:00 on April 25)	O.P.+ 3,253 mm (12 mm decrease since 16:00 on April 25)	O.P.+ 3,163 mm (9 mm decrease since 16:00 on April 25)	O.P.+ 3,100 mm (9 mm decrease since 16:00 on April 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,869 mm (Increase from initial level:4,086 mm, 57 mm decrease since 16:00 on April 25) O.P.+ 3,897 mm (Increase from initial level:4,623 mm, 275 mm increase since 16:00 on April 25) O.P.+ 4,401 mm (Water level from floor:605 mm, 10 mm increase since 16:00 on April 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:27 on April 14)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 9:33 on April 20 to 7:31 on April 26)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:32 on March 28 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 16:28 on April 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	From 3:08 pm on April 25 to 7:38 am on April 26, we transferred the accumulated water from the trench (common pool duct) between the Centralized Radiation Waste Treatment Facility (Process Main Building) and the Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) to the Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building).				

For quick publication of the data of water level, values are provided as reference values.