

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on April 26)**

|  |  |   |  |   |  |
|--|--|---|--|---|--|
| Water Level of the accumulated water<br>(at 16:00 on April 26) |  | Unit 1  | Unit 2   | Unit 3  | Unit 4   |
|  | Water level of Vertical Shaft  | Unmeasurable due to drawdown of water level<br>(Less than O.P.+ 850 mm)   | O.P.+ 3,103 mm<br>(7 mm decrease since 7:00 on April 26)   | O.P.+ 3,140 mm<br>(No change since 7:00 on April 26)      | —  |
|  | Water level of Turbine Building  | O.P.+ 3,258 mm<br>(5 mm increase since 7:00 on April 26)  | O.P.+ 3,052 mm<br>(6 mm decrease since 7:00 on April 26)   | O.P.+ 3,102 mm<br>(21 mm increase since 7:00 on April 26) | O.P.+ 3,077 mm<br>(3 mm decrease since 7:00 on April 26) |
|  | Water level of Reactor Building  | O.P.+ 4,131 mm<br>(12 mm decrease since 7:00 on April 26)   | O.P.+ 3,244 mm<br>(9 mm decrease since 7:00 on April 26)   | O.P.+ 3,181 mm<br>(18 mm increase since 7:00 on April 26) | O.P.+ 3,098 mm<br>(2 mm decrease since 7:00 on April 26) |
|  | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building<br>High Temperature Incinerator Building<br>On-site Bunker Building   | O.P.+ 2,868 mm (Increase from initial level:4,085 mm, 1 mm decrease since 7:00 on April 26)<br>O.P.+ 3,707 mm (Increase from initial level:4,433 mm, 190 mm decrease since 7:00 on April 26)<br>O.P.+ 4,409 mm (Water level from floor:613 mm, 8 mm increase since 7:00 on April 26) |   |  |
| Situation of transfer of the accumulated water                 |  | Unit 1  | Unit 2 * 1   | Unit 3  | Unit 4   |
|  |  | —   | Basement of Unit 2 Turbine Building<br>→Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building)<br>Currently being transferred (Since 15:27 on April 14)  | —   | —  |
|  |  | Unit 5 and 6  |  |   |  |
|  |  | Basement of Unit 6 Turbine Building<br>→Temporary Tank<br>— (From 10:00 on April 26 to 16:00 on April 26)   |  |   |  |
| Operation condition of water treatment facility                |  | Cesium Adsorption Apparatus: Since 9:50 on April 26   Suspended<br>2nd Cesium Adsorption Apparatus (Sarry): Since 16:28 on April 18   In operation<br>Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance<br>Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance |  |   |  |
| Notes  |  |   |  |   |  |

For quick publication of the data of water level, values are provided as reference values.