

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 27)**

| | | | | | |
|---|--|---|---|---|---|
| Water Level of the accumulated water (at 7:00 on April 27) | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | Water level of Vertical Shaft | Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm) | O.P.+ 3,090 mm (13 mm decrease since 16:00 on April 26) | O.P.+ 3,155 mm (15 mm increase since 16:00 on April 26) | — |
| | Water level of Turbine Building | O.P.+ 3,265 mm (7 mm increase since 16:00 on April 26) | O.P.+ 3,040 mm (12 mm decrease since 16:00 on April 26) | O.P.+ 3,120 mm (18 mm increase since 16:00 on April 26) | O.P.+ 3,085 mm (8 mm increase since 16:00 on April 26) |
| | Water level of Reactor Building | O.P.+ 4,163 mm (32 mm increase since 16:00 on April 26) | O.P.+ 3,231 mm (13 mm decrease since 16:00 on April 26) | O.P.+ 3,203 mm (22 mm increase since 16:00 on April 26) | O.P.+ 3,105 mm (7 mm increase since 16:00 on April 26) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | O.P.+ 2,879 mm (Increase from initial level:4,096 mm, 11 mm increase since 16:00 on April 26) O.P.+ 3,480 mm (Increase from initial level:4,206 mm, 227 mm decrease since 16:00 on April 26) O.P.+ 4,419 mm (Water level from floor:623 mm, 10 mm increase since 16:00 on April 26) | | |
| Situation of transfer of the accumulated water | | Unit 1 | Unit 2 * 1 | Unit 3 | Unit 4 |
| | | — | Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:27 on April 14) | Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 9:33 on April 20 to 7:31 on April 26) | — |
| | | Unit 5 and 6 | | | |
| | | — | | | |
| Operation condition of water treatment facility | | Cesium Adsorption Apparatus: Since 14:32 on March 28 In operation 2nd Cesium Adsorption Apparatus (Sarry): From 16:28 on April 18 to 8:33 on April 27 Operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance | | | |
| Notes | At 8:33 am on April 27, we temporarily stopped the 2nd Cesium Adsorption Apparatus (Sarry) for washing of the filter | | | | |

For quick publication of the data of water level, values are provided as reference values.