

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on May 2)**

Water Level of the accumulated water (at 16:00 on May 2)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,114 mm (23 mm increase since 7:00 on May 2)	O.P.+ 3,151 mm (4 mm decrease since 7:00 on May 2)	—
	Water level of Turbine Building	O.P.+ 2,646 mm (5 mm increase since 7:00 on May 2)	O.P.+ 3,061 mm (22 mm increase since 7:00 on May 2)	O.P.+ 3,087 mm (6 mm decrease since 7:00 on May 2)	O.P.+ 3,091 mm (6 mm decrease since 7:00 on May 2)
	Water level of Reactor Building	O.P.+ 4,129 mm (1 mm decrease since 7:00 on May 2)	O.P.+ 3,245 mm (21 mm increase since 7:00 on May 2)	O.P.+ 3,172 mm (6 mm decrease since 7:00 on May 2)	O.P.+ 3,109 mm (6 mm decrease since 7:00 on May 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,040 mm (Increase from initial level:4,257 mm, 8 mm increase since 7:00 on May 2) O.P.+ 3,063 mm (Increase from initial level:3,789 mm, 144 mm decrease since 7:00 on May 2) O.P.+ 4,309 mm (Water level from floor:513 mm, 5 mm increase since 7:00 on May 2)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:43 on April 29)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:42 on April 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.