

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 7)**

Water Level of the accumulated water (at 7:00 on May 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,179 mm (4 mm decrease since 16:00 on May 6)	O.P.+ 3,234 mm (2 mm decrease since 16:00 on May 6)	—
	Water level of Turbine Building	O.P.+ 2,823 mm (22 mm increase since 16:00 on May 6)	O.P.+ 3,119 mm (3 mm decrease since 16:00 on May 6)	O.P.+ 3,163 mm (4 mm decrease since 16:00 on May 6)	O.P.+ 3,158 mm (3 mm decrease since 16:00 on May 6)
	Water level of Reactor Building	O.P.+ 4,598 mm (23 mm decrease since 16:00 on May 6)	O.P.+ 3,311 mm (3 mm decrease since 16:00 on May 6)	O.P.+ 3,252 mm (5 mm decrease since 16:00 on May 6)	O.P.+ 3,175 mm (1 mm decrease since 16:00 on May 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,123 mm (Increase from initial level:4,340 mm, 10 mm increase since 16:00 on May 6) O.P.+ 2,527 mm (Increase from initial level:3,253 mm, 81 mm increase since 16:00 on May 6) O.P.+ 4,388 mm (Water level from floor:592 mm, 10 mm increase since 16:00 on May 6)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:52 on May 3)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:46 on May 5)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:42 on April 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.