

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on May 7)**

Water Level of the accumulated water (at 16:00 on May 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,177 mm (2 mm decrease since 7:00 on May 7)	O.P.+ 3,234 mm (No change since 7:00 on May 7)	—
	Water level of Turbine Building	O.P.+ 2,836 mm (13 mm increase since 7:00 on May 7)	O.P.+ 3,116 mm (3 mm decrease since 7:00 on May 7)	O.P.+ 3,158 mm (5 mm decrease since 7:00 on May 7)	O.P.+ 3,154 mm (4 mm decrease since 7:00 on May 7)
	Water level of Reactor Building	O.P.+ 4,569 mm (29 mm decrease since 7:00 on May 7)	O.P.+ 3,309 mm (2 mm decrease since 7:00 on May 7)	O.P.+ 3,248 mm (4 mm decrease since 7:00 on May 7)	O.P.+ 3,173 mm (2 mm decrease since 7:00 on May 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,133 mm (Increase from initial level:4,350 mm, 10 mm increase since 7:00 on May 7) O.P.+ 2,579 mm (Increase from initial level:3,305 mm, 52 mm increase since 7:00 on May 7) O.P.+ 4,393 mm (Water level from floor:597 mm, 5 mm increase since 7:00 on May 7)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:52 on May 3)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:46 on May 5)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on May 7 to 16:00 on May 7)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:42 on April 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.