

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 8)**

Water Level of the accumulated water (at 7:00 on May 8)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,170 mm (7 mm decrease since 16:00 on May 7)	O.P.+ 3,228 mm (6 mm decrease since 16:00 on May 7)	—
	Water level of Turbine Building	O.P.+ 2,856 mm (20 mm increase since 16:00 on May 7)	O.P.+ 3,110 mm (6 mm decrease since 16:00 on May 7)	O.P.+ 3,152 mm (6 mm decrease since 16:00 on May 7)	O.P.+ 3,152 mm (2 mm decrease since 16:00 on May 7)
	Water level of Reactor Building	O.P.+ 4,536 mm (33 mm decrease since 16:00 on May 7)	O.P.+ 3,306 mm (3 mm decrease since 16:00 on May 7)	O.P.+ 3,243 mm (5 mm decrease since 16:00 on May 7)	O.P.+ 3,167 mm (6 mm decrease since 16:00 on May 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,142 mm (Increase from initial level:4,359 mm, 9 mm increase since 16:00 on May 7) O.P.+ 2,654 mm (Increase from initial level:3,380 mm, 75 mm increase since 16:00 on May 7) O.P.+ 4,404 mm (Water level from floor:608 mm, 11 mm increase since 16:00 on May 7)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:52 on May 3)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:46 on May 5)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:42 on April 27   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.