

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on May 8)**

Water Level of the accumulated water (at 16:00 on May 8)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,166 mm (4 mm decrease since 7:00 on May 8)	O.P.+ 3,225 mm (3 mm decrease since 7:00 on May 8)	—
	Water level of Turbine Building	O.P.+ 2,867 mm (11 mm increase since 7:00 on May 8)	O.P.+ 3,107 mm (3 mm decrease since 7:00 on May 8)	O.P.+ 3,148 mm (4 mm decrease since 7:00 on May 8)	O.P.+ 3,148 mm (4 mm decrease since 7:00 on May 8)
	Water level of Reactor Building	O.P.+ 4,492 mm (44 mm decrease since 7:00 on May 8)	O.P.+ 3,303 mm (3 mm decrease since 7:00 on May 8)	O.P.+ 3,238 mm (5 mm decrease since 7:00 on May 8)	O.P.+ 3,166 mm (1 mm decrease since 7:00 on May 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,193 mm (Increase from initial level:4,410 mm, 51 mm increase since 7:00 on May 8) O.P.+ 2,599 mm (Increase from initial level:3,325 mm, 55 mm decrease since 7:00 on May 8) O.P.+ 4,410 mm (Water level from floor:614 mm, 6 mm increase since 7:00 on May 8)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:52 on May 3)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:56 on May 8)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:42 on April 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	·9:46 AM on May 5 - 9:42 AM on May 8: Accumulated water was transfered from the underground of Unit 3 Turbine Building to Central Radioactive Waste Treatment Facility (High Temperature Incinerator Building).				

For quick publication of the data of water level, values are provided as reference values.