

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 9)**

Water Level of the accumulated water (at 7:00 on May 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,159 mm (7 mm decrease since 16:00 on May 8)	O.P.+ 3,221 mm (4 mm decrease since 16:00 on May 8)	—
	Water level of Turbine Building	O.P.+ 2,886 mm (19 mm increase since 16:00 on May 8)	O.P.+ 3,102 mm (5 mm decrease since 16:00 on May 8)	O.P.+ 3,141 mm (7 mm decrease since 16:00 on May 8)	O.P.+ 3,143 mm (5 mm decrease since 16:00 on May 8)
	Water level of Reactor Building	O.P.+ 4,472 mm (20 mm decrease since 16:00 on May 8)	O.P.+ 3,298 mm (5 mm decrease since 16:00 on May 8)	O.P.+ 3,231 mm (7 mm decrease since 16:00 on May 8)	O.P.+ 3,160 mm (6 mm decrease since 16:00 on May 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,332 mm (Increase from initial level:4,549 mm, 139 mm increase since 16:00 on May 8) O.P.+ 2,441 mm (Increase from initial level:3,167 mm, 158 mm decrease since 16:00 on May 8) O.P.+ 4,420 mm (Water level from floor:624 mm, 10 mm increase since 16:00 on May 8)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:52 on May 3)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:56 on May 8)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26 Suspended 2nd Cesium Adsorption Apparatus (Sarry): From 12:42 on April 27 to 8:02 on May 9 Operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	· 8:02 AM on May 9: The operation was temporarily stopped at the 2nd Cesium Adsorption Apparatus (Sarry), and the filter cleaning was conducted.				

For quick publication of the data of water level, values are provided as reference values.