

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on May 9)**

Water Level of the accumulated water (at 16:00 on May 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,180 mm (21 mm increase since 7:00 on May 9)	O.P.+ 3,217 mm (4 mm decrease since 7:00 on May 9)	—
	Water level of Turbine Building	O.P.+ 2,897 mm (11 mm increase since 7:00 on May 9)	O.P.+ 3,120 mm (18 mm increase since 7:00 on May 9)	O.P.+ 3,137 mm (4 mm decrease since 7:00 on May 9)	O.P.+ 3,139 mm (4 mm decrease since 7:00 on May 9)
	Water level of Reactor Building	O.P.+ 4,429 mm (43 mm decrease since 7:00 on May 9)	O.P.+ 3,308 mm (10 mm increase since 7:00 on May 9)	O.P.+ 3,226 mm (5 mm decrease since 7:00 on May 9)	O.P.+ 3,157 mm (3 mm decrease since 7:00 on May 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,435 mm (Increase from initial level:4,652 mm, 103 mm increase since 7:00 on May 9) O.P.+ 2,542 mm (Increase from initial level:3,268 mm, 101 mm increase since 7:00 on May 9) O.P.+ 4,425 mm (Water level from floor:629 mm, 5 mm increase since 7:00 on May 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 14:52 on May 3 to 10:30 on May 9)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:56 on May 8)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on May 9 to 16:00 on May 9)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:50 on May 9   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	· At 8:02 AM on May 9, the operation was temporarily stopped at the 2nd Cesium Adsorption Apparatus (Sarry), and the filter cleaning was conducted. After the cleaning, water source was switched from the Miscellaneous Solid Waste Volume Reduction Treatment Building (High Temperature Incinerator Building) to the Process Main Building. This apparatus was started up at 5:29 PM on the same day, and achieved the steady flow at 5:50 PM.				

For quick publication of the data of water level, values are provided as reference values.