

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on May 10)**

Water Level of the accumulated water (at 16:00 on May 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,264 mm (32 mm increase since 7:00 on May 10)	O.P.+ 3,209 mm (3 mm decrease since 7:00 on May 10)	—
	Water level of Turbine Building	O.P.+ 2,924 mm (10 mm increase since 7:00 on May 10)	O.P.+ 3,195 mm (28 mm increase since 7:00 on May 10)	O.P.+ 3,126 mm (5 mm decrease since 7:00 on May 10)	O.P.+ 3,129 mm (3 mm decrease since 7:00 on May 10)
	Water level of Reactor Building	O.P.+ 4,401 mm (13 mm decrease since 7:00 on May 10)	O.P.+ 3,380 mm (25 mm increase since 7:00 on May 10)	O.P.+ 3,217 mm (4 mm decrease since 7:00 on May 10)	O.P.+ 3,149 mm (No change since 7:00 on May 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,282 mm (Increase from initial level:4,499 mm, 67 mm decrease since 7:00 on May 10) O.P.+ 2,577 mm (Increase from initial level:3,303 mm, 14 mm increase since 7:00 on May 10) O.P.+ 4,440 mm (Water level from floor:644 mm, 5 mm increase since 7:00 on May 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 16:02 on May 10)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:56 on May 8)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:50 on May 9 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.