

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 11)**

Water Level of the accumulated water (at 7:00 on May 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,245 mm (19 mm decrease since 16:00 on May 10)	O.P.+ 3,204 mm (5 mm decrease since 16:00 on May 10)	—
	Water level of Turbine Building	O.P.+ 2,940 mm (16 mm increase since 16:00 on May 10)	O.P.+ 3,176 mm (19 mm decrease since 16:00 on May 10)	O.P.+ 3,120 mm (6 mm decrease since 16:00 on May 10)	O.P.+ 3,123 mm (6 mm decrease since 16:00 on May 10)
	Water level of Reactor Building	O.P.+ 4,399 mm (2 mm decrease since 16:00 on May 10)	O.P.+ 3,376 mm (4 mm decrease since 16:00 on May 10)	O.P.+ 3,210 mm (7 mm decrease since 16:00 on May 10)	O.P.+ 3,142 mm (7 mm decrease since 16:00 on May 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,346 mm (Increase from initial level:4,563 mm, 64 mm increase since 16:00 on May 10) O.P.+ 2,589 mm (Increase from initial level:3,315 mm, 12 mm increase since 16:00 on May 10) O.P.+ 4,449 mm (Water level from floor:653 mm, 9 mm increase since 16:00 on May 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 16:02 on May 10)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:56 on May 8)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:50 on May 9   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	At 8:05 AM on May 11, we started transferring the water accumulated in the pit of Unit 3 circulating water pump discharge valve to Unit 2 Turbine Building basement, in order to fill concrete into the pit.				

For quick publication of the data of water level, values are provided as reference values.