

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 14)**

Water Level of the accumulated water (at 7:00 on May 14)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,195 mm (17 mm decrease since 16:00 on May 13)	O.P.+ 3,196 mm (12 mm increase since 16:00 on May 13)	—
	Water level of Turbine Building	O.P.+ 3,014 mm (15 mm increase since 16:00 on May 13)	O.P.+ 3,130 mm (14 mm decrease since 16:00 on May 13)	O.P.+ 3,157 mm (25 mm increase since 16:00 on May 13)	O.P.+ 3,123 mm (5 mm increase since 16:00 on May 13)
	Water level of Reactor Building	O.P.+ 4,344 mm (18 mm decrease since 16:00 on May 13)	O.P.+ 3,331 mm (15 mm decrease since 16:00 on May 13)	O.P.+ 3,247 mm (28 mm increase since 16:00 on May 13)	O.P.+ 3,139 mm (2 mm increase since 16:00 on May 13)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,462 mm (Increase from initial level:4,679 mm, 86 mm decrease since 16:00 on May 13) O.P.+ 2,635 mm (Increase from initial level:3,361 mm, 8 mm increase since 16:00 on May 13) O.P.+ 4,496 mm (Water level from floor:700 mm, 12 mm increase since 16:00 on May 13)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 16:02 on May 10)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:50 on May 9 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	At 8:45 am on May 14, we started the transfer of accumulated water from the On-site Bunker Building to Process Main Building.				

For quick publication of the data of water level, values are provided as reference values.