

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 15)**

Water Level of the accumulated water (at 7:00 on May 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,181 mm (17 mm decrease since 16:00 on May 14)	O.P.+ 3,215 mm (11 mm increase since 16:00 on May 14)	—
	Water level of Turbine Building	O.P.+ 3,036 mm (14 mm increase since 16:00 on May 14)	O.P.+ 3,120 mm (13 mm decrease since 16:00 on May 14)	O.P.+ 3,180 mm (13 mm increase since 16:00 on May 14)	O.P.+ 3,140 mm (10 mm increase since 16:00 on May 14)
	Water level of Reactor Building	O.P.+ 4,299 mm (10 mm decrease since 16:00 on May 14)	O.P.+ 3,322 mm (10 mm decrease since 16:00 on May 14)	O.P.+ 3,271 mm (14 mm increase since 16:00 on May 14)	O.P.+ 3,155 mm (10 mm increase since 16:00 on May 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,452 mm (Increase from initial level:4,669 mm, 71 mm decrease since 16:00 on May 14) O.P.+ 2,655 mm (Increase from initial level:3,381 mm, 9 mm increase since 16:00 on May 14) O.P.+ 4,236 mm (Water level from floor:440 mm, 16 mm decrease since 16:00 on May 14)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:35 on May 15)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:58 on May 15)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:41 on May 15 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	・From 4:02 PM on May 10 to 8:25 AM May 15, transfer of the accumulated water from the Turbine Building basement of Unit 2 to Process Main Building was conducted. * Due to the vessel replacement, transfer is stopped temporarily.				

For quick publication of the data of water level, values are provided as reference values.