

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on May 15)**

Water Level of the accumulated water (at 16:00 on May 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,188 mm (7 mm increase since 7:00 on May 15)	O.P.+ 3,211 mm (4 mm decrease since 7:00 on May 15)	—
	Water level of Turbine Building	O.P.+ 3,044 mm (8 mm increase since 7:00 on May 15)	O.P.+ 3,126 mm (6 mm increase since 7:00 on May 15)	O.P.+ 3,168 mm (12 mm decrease since 7:00 on May 15)	O.P.+ 3,146 mm (6 mm increase since 7:00 on May 15)
	Water level of Reactor Building	O.P.+ 4,300 mm (1 mm increase since 7:00 on May 15)	O.P.+ 3,327 mm (5 mm increase since 7:00 on May 15)	O.P.+ 3,263 mm (8 mm decrease since 7:00 on May 15)	O.P.+ 3,160 mm (5 mm increase since 7:00 on May 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,453 mm (Increase from initial level:4,670 mm, 1 mm increase since 7:00 on May 15) O.P.+ 3,008 mm (Increase from initial level:3,734 mm, 353 mm increase since 7:00 on May 15) O.P.+ 4,241 mm (Water level from floor:445 mm, 5 mm increase since 7:00 on May 15)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:35 on May 15)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:58 on May 15)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:41 on May 15 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	Due to the vessel replacement, transfer is stopped temporarily. ・ At 8:41 AM on May 15, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY), and conducted the cleaning of filter.				

For quick publication of the data of water level, values are provided as reference values.