

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 16)**

Water Level of the accumulated water (at 7:00 on May 16)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,175 mm (13 mm decrease since 16:00 on May 15)	O.P.+ 3,207 mm (4 mm decrease since 16:00 on May 15)	—
	Water level of Turbine Building	O.P.+ 3,059 mm (15 mm increase since 16:00 on May 15)	O.P.+ 3,117 mm (9 mm decrease since 16:00 on May 15)	O.P.+ 3,150 mm (18 mm decrease since 16:00 on May 15)	O.P.+ 3,142 mm (4 mm decrease since 16:00 on May 15)
	Water level of Reactor Building	O.P.+ 4,328 mm (28 mm increase since 16:00 on May 15)	O.P.+ 3,321 mm (6 mm decrease since 16:00 on May 15)	O.P.+ 3,245 mm (18 mm decrease since 16:00 on May 15)	O.P.+ 3,159 mm (1 mm decrease since 16:00 on May 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,468 mm (Increase from initial level:4,685 mm, 15 mm increase since 16:00 on May 15) O.P.+ 3,257 mm (Increase from initial level:3,983 mm, 249 mm increase since 16:00 on May 15) O.P.+ 4,248 mm (Water level from floor:452 mm, 7 mm increase since 16:00 on May 15)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:35 on May 15)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:58 on May 15)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 18:16 on May 15   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* From 8:41 AM to 6:16 PM on May 15, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for vessel replacement and filter cleaning.				

For quick publication of the data of water level, values are provided as reference values.