

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 17)**

Water Level of the accumulated water (at 7:00 on May 17)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,170 mm (11 mm decrease since 16:00 on May 16)	O.P.+ 3,195 mm (6 mm decrease since 16:00 on May 16)	—
	Water level of Turbine Building	O.P.+ 3,080 mm (13 mm increase since 16:00 on May 16)	O.P.+ 3,109 mm (11 mm decrease since 16:00 on May 16)	O.P.+ 3,131 mm (11 mm decrease since 16:00 on May 16)	O.P.+ 3,131 mm (7 mm decrease since 16:00 on May 16)
	Water level of Reactor Building	O.P.+ 4,325 mm (5 mm decrease since 16:00 on May 16)	O.P.+ 3,312 mm (11 mm decrease since 16:00 on May 16)	O.P.+ 3,224 mm (12 mm decrease since 16:00 on May 16)	O.P.+ 3,148 mm (7 mm decrease since 16:00 on May 16)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,487 mm (Increase from initial level:4,704 mm, 12 mm increase since 16:00 on May 16) O.P.+ 3,466 mm (Increase from initial level:4,192 mm, 127 mm increase since 16:00 on May 16) O.P.+ 4,260 mm (Water level from floor:464 mm, 7 mm increase since 16:00 on May 16)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:35 on May 15)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (From 8:58 on May 15 to 8:11 on May 17)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 18:16 on May 15 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.