

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on May 17)**

| | | | | | |
|--|--|---|---|---|--|
| Water Level of the accumulated water (at 16:00 on May 17) | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | Water level of Vertical Shaft | Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm) | O.P.+ 3,173 mm (3 mm increase since 7:00 on May 17) | O.P.+ 3,196 mm (1 mm increase since 7:00 on May 17) | — |
| | Water level of Turbine Building | O.P.+ 3,088 mm (8 mm increase since 7:00 on May 17) | O.P.+ 3,114 mm (5 mm increase since 7:00 on May 17) | O.P.+ 3,150 mm (19 mm increase since 7:00 on May 17) | O.P.+ 3,129 mm (2 mm decrease since 7:00 on May 17) |
| | Water level of Reactor Building | O.P.+ 4,302 mm (23 mm decrease since 7:00 on May 17) | O.P.+ 3,315 mm (3 mm increase since 7:00 on May 17) | O.P.+ 3,243 mm (19 mm increase since 7:00 on May 17) | O.P.+ 3,146 mm (2 mm decrease since 7:00 on May 17) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | O.P.+ 3,503 mm (Increase from initial level:4,720 mm, 16 mm increase since 7:00 on May 17) O.P.+ 3,364 mm (Increase from initial level:4,090 mm, 102 mm decrease since 7:00 on May 17) O.P.+ 4,265 mm (Water level from floor:469 mm, 5 mm increase since 7:00 on May 17) | | |
| Situation of transfer of the accumulated water | | Unit 1 | Unit 2 * 1 | Unit 3 | Unit 4 |
| | | — | Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:35 on May 15) | — | — |
| | | Unit 5 and 6 | | | |
| | | — | | | |
| Operation condition of water treatment facility | | Cesium Adsorption Apparatus: Since 9:50 on April 26 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 18:16 on May 15 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance | | | |
| Notes | | | | | |

For quick publication of the data of water level, values are provided as reference values.