

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on May 21)**

Water Level of the accumulated water (at 16:00 on May 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,131 mm (5 mm decrease since 7:00 on May 21)	O.P.+ 3,223 mm (3 mm decrease since 7:00 on May 21)	—
	Water level of Turbine Building	O.P.+ 3,174 mm (8 mm increase since 7:00 on May 21)	O.P.+ 3,076 mm (5 mm decrease since 7:00 on May 21)	O.P.+ 3,160 mm (5 mm decrease since 7:00 on May 21)	O.P.+ 3,155 mm (3 mm decrease since 7:00 on May 21)
	Water level of Reactor Building	O.P.+ 4,387 mm (23 mm decrease since 7:00 on May 21)	O.P.+ 3,282 mm (4 mm decrease since 7:00 on May 21)	O.P.+ 3,256 mm (4 mm decrease since 7:00 on May 21)	O.P.+ 3,170 mm (5 mm decrease since 7:00 on May 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,580 mm (Increase from initial level:4,797 mm, 12 mm increase since 7:00 on May 21) O.P.+ 3,147 mm (Increase from initial level:3,873 mm, 71 mm increase since 7:00 on May 21) O.P.+ 4,314 mm (Water level from floor:518 mm, 4 mm increase since 7:00 on May 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:35 on May 15)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:15 on May 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 18:16 on May 15 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.