

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on May 22)**

Water Level of the accumulated water (at 16:00 on May 22)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,119 mm (3 mm decrease since 7:00 on May 22)	O.P.+ 3,214 mm (3 mm decrease since 7:00 on May 22)	—
	Water level of Turbine Building	O.P.+ 3,193 mm (6 mm increase since 7:00 on May 22)	O.P.+ 3,066 mm (3 mm decrease since 7:00 on May 22)	O.P.+ 3,148 mm (3 mm decrease since 7:00 on May 22)	O.P.+ 3,145 mm (3 mm decrease since 7:00 on May 22)
	Water level of Reactor Building	O.P.+ 4,347 mm (16 mm decrease since 7:00 on May 22)	O.P.+ 3,272 mm (4 mm decrease since 7:00 on May 22)	O.P.+ 3,242 mm (5 mm decrease since 7:00 on May 22)	O.P.+ 3,159 mm (4 mm decrease since 7:00 on May 22)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,601 mm (Increase from initial level:4,818 mm, 8 mm increase since 7:00 on May 22) O.P.+ 3,322 mm (Increase from initial level:4,048 mm, 69 mm increase since 7:00 on May 22) O.P.+ 4,326 mm (Water level from floor:530 mm, 5 mm increase since 7:00 on May 22)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:35 on May 15)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:15 on May 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 18:16 on May 15   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.