

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 24)**

Water Level of the accumulated water (at 7:00 on May 24)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,110 mm (7 mm decrease since 16:00 on May 23)	O.P.+ 3,210 mm (5 mm decrease since 16:00 on May 23)	—
	Water level of Turbine Building	O.P.+ 3,232 mm (13 mm increase since 16:00 on May 23)	O.P.+ 3,058 mm (5 mm decrease since 16:00 on May 23)	O.P.+ 3,144 mm (5 mm decrease since 16:00 on May 23)	O.P.+ 3,139 mm (3 mm decrease since 16:00 on May 23)
	Water level of Reactor Building	O.P.+ 4,495 mm (41 mm increase since 16:00 on May 23)	O.P.+ 3,267 mm (6 mm decrease since 16:00 on May 23)	O.P.+ 3,240 mm (6 mm decrease since 16:00 on May 23)	O.P.+ 3,153 mm (4 mm decrease since 16:00 on May 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,883 mm (Increase from initial level:5,100 mm, 190 mm increase since 16:00 on May 23) O.P.+ 3,482 mm (Increase from initial level:4,208 mm, 220 mm decrease since 16:00 on May 23) O.P.+ 4,345 mm (Water level from floor:549 mm, 8 mm increase since 16:00 on May 23)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:15 on May 23)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:15 on May 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:05 on May 23   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.