

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on May 24)**

| | | | | | |
|--------------------------------------------------------------|------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------|
| Water Level of the accumulated water (at 16:00 on May 24) | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | Water level of Vertical Shaft | Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm) | O.P.+ 3,108 mm (2 mm decrease since 7:00 on May 24) | O.P.+ 3,208 mm (2 mm decrease since 7:00 on May 24) | — |
| | Water level of Turbine Building | O.P.+ 3,240 mm (8 mm increase since 7:00 on May 24) | O.P.+ 3,055 mm (3 mm decrease since 7:00 on May 24) | O.P.+ 3,140 mm (4 mm decrease since 7:00 on May 24) | O.P.+ 3,137 mm (2 mm decrease since 7:00 on May 24) |
| | Water level of Reactor Building | O.P.+ 4,477 mm (18 mm decrease since 7:00 on May 24) | O.P.+ 3,264 mm (3 mm decrease since 7:00 on May 24) | O.P.+ 3,237 mm (3 mm decrease since 7:00 on May 24) | O.P.+ 3,152 mm (1 mm decrease since 7:00 on May 24) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | O.P.+ 4,000 mm (Increase from initial level:5,217 mm, 117 mm increase since 7:00 on May 24) O.P.+ 3,329 mm (Increase from initial level:4,055 mm, 153 mm decrease since 7:00 on May 24) O.P.+ 4,350 mm (Water level from floor:554 mm, 5 mm increase since 7:00 on May 24) | | |
| Situation of transfer of the accumulated water | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | | — | Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:15 on May 23) | Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:15 on May 19) | — |
| | | Unit 5 and 6 | | | |
| | | — | | | |
| Operation condition of water treatment facility | | Cesium Adsorption Apparatus: Since 9:50 on April 26 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:05 on May 23 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance | | | |
| Notes | | | | | |

For quick publication of the data of water level, values are provided as reference values.